



Automatic Fire Sprinkler Affidavit for Alterations or Tenant Improvement

(1-20 Sprinkler Heads- Without Stamped Plans)

In accordance with the Code of the Town of Brighton and the New York State Fire Prevention and Building Code, a Fire Sprinkler Affidavit for Alteration or Tenant Improvement operational permit is required to install, alter or modify an automatic fire sprinkler system

Applicant & Property Information	Make Checks Payable – Town of Brighton				Alterations or Tenant Improvements Permit Application - \$50.00			
	Business Name							
	Address			Suite	City		State	Zip Code
	Telephone		Work Telephone			Email Address		
Installation Company / Agent	Name							
	Contact Name							
	Address				City		State	Zip Code
	Telephone		Mobile Telephone			Work Telephone		
System Information	NFPA 13	NFPA 13R	NFPA 13D	NEW	REMODEL	ALTERATION / ADDITION		
	QUICK RESPONSE	STANDARD RESPONSE	EXTENDED COVERAGE	EARLY SUPPRESSION FAST RESPONSE	PENDENT	UPRIGHT	SIDEWALL	
	LIGHT HAZARD	ORDINARY HAZARD GROUP 1	ORDINARY HAZARD GROUP 2	EXTRA HAZARD GROUP 1	EXTRA HAZARD GROUP 2			
	INDICATE NUMBER OF HEADS INSTALLED OR TO BE WORKED ON							
	ADDED	RELOCATED	PLUGGED	LOWERED	UPSIZED PIPING			
	ALTERED ABOVE CEILING		ALTERED BELOW CEILING					
	DESCRIPTION OF WORK TO BE DONE							

I understand a reflective ceiling plan sketch is required to be attached to this application detailing the area of work within the building's structure, and a copy of this document shall be available for all inspections.

By signing below, I hereby apply for a Fire Protection System Installation permit and certify that I have read and understand the information package for the installation requirements pertinent to this permit and agree to abide by them. This application for a Fire Code Operational Permit will be in accordance with all ordinances of the Town of Brighton and the Fire and Building Code of New York State and that any plans or specifications submitted with this application are the plans or specifications relating to this permit.

I further understand this is not a permit but only an application for permit and construction work is not to start without a permit; that the work will be in accordance with the approved plans.

Applicant Signature	Applicant Name (Print)	Application Date
---------------------	------------------------	------------------

Automatic Fire Sprinkler Affidavit for Alterations or Tenant Improvement Requirements

This affidavit cannot be submitted when flexible piping products are going to be used.

The use of flexible piping products will require a full set of plans and calculations to be submitted for review.

I understand a reflective ceiling plan sketch is required to be attached to this application detailing the area of work within the building's structure, and a copy of this document shall be available for all inspections.

There is no change in occupancy classification or hazard classification.

Addition of sprinklers when the Room Design method (NFPA 13; 11.2.3.3) is used, if it is clearly explained and easily apparent that the additional piping/head(s) will not exceed the hydraulic design of the existing system and the following information is shown on the plans:

1. Wall fire-resistance rating (NFPA 13: 11.2.3.3.3; must meet Table 11.2.3.1.2, 30-minute minimum is required), and
2. Door lintel height (8" minimum; 13: 11.2.3.3.5(2) and
3. Opening protection (Must meet 13:11.2.3.3.5). This information is required to verify applicability and design area.

All work is limited to drops and armovers in a light-hazard occupancy with like sprinkler heads, i.e standard response and quick response.

Positions of sprinkler heads relative to architectural features such as soffits, beams, partitions, walls, etc. complies with the current adopted edition of NFPA 13.

The proposed work does not require hydraulic calculations because sprinklers use standard spacing and are not extended coverage or other specialized type of sprinkler.

Only one sprinkler head will be installed from one drop
(exception: up to two heads from one drop may be installed when each head is in a separate fire area).

The area covered per sprinkler head is limited to the spacing requirements of NFPA 13.

Tenant improvements in a new building shall be equipped with Quick Response heads *(see 2016 NFPA 13, Section 8.3.3.1)*

The installation shall comply with the requirements of the current adopted edition of NFPA 13.

Deficiencies caused by tenant finish or remodel work shall be corrected prior to final inspection. This means if the scope of work causes a deficiency in the system, that deficiency becomes your responsibility to correct.

For example, a demising wall is erected for a new tenant and that demising wall creates a spacing issue of sprinklers outside the new tenant space, you must correct that spacing issue prior to final inspection. Office of the Fire Marshal will consider that as part of your scope of work.

Piping shall not be concealed until hangers and bracing are inspected.

Sprinklers removed for any reason shall NOT be reinstalled per NFPA 13, 6.2.1.1.

Final Certificate of Compliance shall be subject to onsite inspection, tests and inspections.

A statement of compliance, with the minimum information as specified in 2020 Fire Code of New York State - Section 901.2.1, will be given to the Office of the Fire Marshal prior to or at final Certificate of Compliance inspection.